

Certificate

Registration No.: PV 60039716

Page 1

Report No.: 21164795.001

License Holder:

Elettrotek Srl

Galleria San Giacomo 16
41013 Castelfranco Emilia (MO)
Italy

Product:

PV Module

Type:

ETK-M672*** (***) = 250 - 300, in increments of 5)
ETK-M660*** (***) = 215 - 255, in increments of 5)
ETK-M654*** (***) = 190 - 230, in increments of 5)

ETK-P672*** (***) = 245 - 295, in increments of 5)
ETK-P660*** (***) = 200 - 240, in increments of 5)
ETK-P654*** (***) = 180 - 220, in increments of 5)

ETK-M572*** (***) = 165 - 195, in increments of 5)
ETK-M596*** (***) = 220 - 260, in increments of 5)

Manufacturing Plant:

0010--21164795 001

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The above listed PV modules fulfil the requirements of fire rating class **C**.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 27 February 2016.

Cologne, 22 June 2011



Dipl.-Ing. M. Adrian